

## Water Testing Results - Long Creek School Main Building

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
South Sink, West Girls Restroom	20120100-001BF	1/28/2022	0.64
North Sink, West Girls Restroom	20120100-002BF	1/28/2022	ND
West Faucet, West Janitor's Room	20120100-003SF	1/28/2022	0.887
East Faucet, West Janitor's Room	20120100-004SF	1/28/2022	0.666
West Sink, West Boys Restroom -	20120100-005BF	1/28/2022	0.863
East Sink, West Boys Restroom	20120100-006BF	1/28/2022	0.942
ELC Sink	20120100-007CF	1/28/2022	1.15
Home Ec Room Sink	20120100-008CF	1/28/2022	ND
West Kitchen Sprayer	20120100-009KF	1/28/2022	0.728
West Kitchen Sink	20120100-010KF	1/28/2022	35
East Kitchen Sink	20120100-011KF	1/28/2022	0.563
East Kitchen Sprayer	20120100-012KF	1/28/2022	0.794
Library Sink	20120100-013CF	1/28/2022	ND
West Double Sink, Science Lab	20120100-014CF	1/28/2022	28.3
North West Sink, Science Lab	20120100-015CF	1/28/2022	9.31
North Sink, Science Lab	20120100-018CF	1/28/2022	3.25
North East Sink, Science Lab	20120100-019CF	1/28/2022	5.86
East Sink, Science Lab	20120100-020CF	1/28/2022	8.86
Nurse's Office Sink	20120100-021NS	1/28/2022	1.45
South Sink, East Boys Restroom	20120100-022BF	1/28/2022	1.31
Middle Sink, East Boys Restroom	20120100-023BF	1/28/2022	1.09
North Sink, East Boys Restroom	20120100-024BF	1/28/2022	0.556
East Janitor's Closet Sink	20120100-025SF	1/28/2022	4.44
South Sink, East Girls Restroom	20120100-027BF	1/28/2022	4.15
2nd Sink from right, East Girls Restroom	20120100-028BF	1/28/2022	1.93
North Sink, East Girls Restroom	20120100-029BF	1/28/2022	8.53
Staff Room Sink	20120100-030SF	1/28/2022	1.34
Sink Faucet, English Classroom	20120100-031CF	1/28/2022	3.38
Sink Faucet, Jr-High Classroom	20120100-033CF	1/28/2022	1.92
Sink Faucet, 4-6 Classroom	20120100-035CF	1/28/2022	9.87
Drinking Faucet, 4-6 Classroom	20120100-036CF	1/28/2022	3.4
Sink Faucet, East Computer Lab	20120100-037CF	1/28/2022	3.36
Sink Faucet, K-3 Classroom	20120100-039CF	1/28/2022	1.18
Sink Faucet, Art Room	20120100-041CF	1/28/2022	5.67
East Girls Restroom, 3rd sink from right	20120100-043CF	1/28/2022	1.81
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS - Passed			
West Kitchen Sink	20120100-010KF	5/14/2022	1.07
West Double Sink, Science Lab	20120100-014CF	5/14/2022	3.11
ND = Non Detect - Lead level is below the set detection limits of X ppb			

**Water Testing Results - Long Creek School District**  
**LCSD Bus Barn Standpipe and Rentals.**  
**Action Level is 15 parts per billion (ppb)**

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Bus Barn Standpipe	20120104-001OS	5/14/2022	8.74
<b>Rentals:</b>			
325 E. Main St. Rental - Bath. Sink Faucet	20120105-001BF	5/14/2022	ND
325 E. Main St. Rental - Bath. Tub Faucet	20120105-002BF	5/14/2022	ND
325 E. Main St. Rental - Kitchen	20120105-003KF	5/14/2022	ND
210 N. Bradley St. Rental - Kitchen Sink Faucet	20120106-001KF	5/14/2022	ND
210 N. Bradley Rental - Mast. Bath. Sink Faucet	20120106-002BF	5/14/2022	ND
210 N. Bradley Rental - Mast. Bath. Tub Facuet	20120106-003BF	5/14/2022	ND
210 N. Bradley Rental - Main Bath. Sink Facuet	20120106-004BF	5/14/2022	ND
210 N. Bradley Rental - Main Bath. Tub Facuet	20120106-005BF	5/14/2022	ND
230 Bradley Rental - N. Side Bath. Sink Faucet	20120107-001BF	5/14/2022	0.985
230 Bradley Rental - N. Side Bath. Tub Faucet	20120107-002BF	5/14/2022	3.97
230 Bradley Rental - S. Side Bath. Sink Faucet	20120107-003BF	5/14/2022	1.32
230 Bradley Rental - S. Side Bath. Tub Faucet	20120107-004BF	5/14/2022	0.768
230 Bradley Rental - N. Side Kitchen Sink	20120107-005KF	5/14/2022	0.756
230 Bradley Rental - S. Side Kitchen Sink	20120107-006KF	5/14/2022	4.31
230 Bradley Rental - Extra Bathroom Sink	20120107-007BF	5/14/2022	ND
323 E. Main St. Rental - Kitchen Sink Faucet	20120110-001KF	5/14/2022	ND
323 E. Main St. Rental - Mast. Bath. Sink Faucet	20120110-002BF	5/14/2022	ND
323 E. Main St. Rental - Mast. Bath. Tub Faucet	20120110-003BF	5/14/2022	ND
323 E. Main St. Rental - Main Bath. Sink Faucet	20120110-004BF	5/14/2022	ND
323 E. Main St. Rental - Main Bath. Tub Faucet	20120110-005BF	5/14/2022	ND
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS			
ND = Non Detect - Lead level is below the set detection limits			of 1 ppb





Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-01      Client Sample ID: Bottle #106327  
 Collection Date: 5/14/2022 10:30:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: West Kitchen Sink Faucet-Cafeteria

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.07		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-02      Client Sample ID: Bottle #106330  
 Collection Date: 5/14/2022 10:30:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Science Lab-West Double Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.11		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-03      Client Sample ID: Bottle #106326  
 Collection Date: 5/14/2022 10:35:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Bus Barn Standpipe

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.74		0.500	ppb	1	6/4/2022	15.0	A	

**QUALIFIERS**  
**NELAP**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-04      Client Sample ID: Bottle #106349  
 Collection Date: 5/14/2022 10:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 325 Rental Bathroom Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-05      Client Sample ID: Bottle #106342  
 Collection Date: 5/14/2022 10:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 325 Rental Bathroom Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-06      Client Sample ID: Bottle #106341  
 Collection Date: 5/14/2022 10:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 325 Rental Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrelabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-07      Client Sample ID: Bottle #106347  
 Collection Date: 5/14/2022 10:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 210 N Bradley Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-08      Client Sample ID: Bottle #106351  
 Collection Date: 5/14/2022 10:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 210 N Bradley Master Bath Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-09      Client Sample ID: Bottle #106339  
 Collection Date: 5/14/2022 10:15:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 210 N Bradley Master Bath Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-10      Client Sample ID: Bottle #106332B  
 Collection Date: 5/14/2022 10:15:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 210 N Bradley Main Bath Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-11      Client Sample ID: Bottle #106322A  
 Collection Date: 5/14/2022 10:15:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 210 N Bradley Main Bath Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-12      Client Sample ID: Bottle #106346  
 Collection Date: 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 230 N Bradley N Side Bath Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.985		0.500	ppb	1	6/8/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-13      Client Sample ID: Bottle #106337  
**Collection Date:** 5/14/2022 8:30:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: 230 N Bradley N Side Bath Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.97		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-14      Client Sample ID: Bottle #106331  
**Collection Date:** 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: 230 N Bradley S Side Bath Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.32		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-15      Client Sample ID: Bottle #106333  
**Collection Date:** 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: 230 N Bradley S Side Bath Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.768		0.500	ppb	1	6/4/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original





Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

Lab Order: 22051027  
 Received Date: 5/23/2022 11:00:00 AM  
 Reported Date: 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

Lab ID: 22051027-16 Client Sample ID: Bottle #106311  
 Collection Date: 5/14/2022 8:30:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: 230 N Bradley N Side Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.756		0.500	ppb	1	6/4/2022	15.0	A

Lab ID: 22051027-17 Client Sample ID: Bottle #106317  
 Collection Date: 5/14/2022 9:15:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: 230 N Bradley S Side Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.31		0.500	ppb	1	6/4/2022	15.0	A

Lab ID: 22051027-18 Client Sample ID: Bottle #106313  
 Collection Date: 5/14/2022 9:15:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: 230 N Bradley Extra Bathroom Sink


Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A

**QUALIFIERS**  
**NELAP**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-19      Client Sample ID: Bottle #106323  
 Collection Date: 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 323 E Main St Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-20      Client Sample ID: Bottle #106350  
 Collection Date: 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 323 E Main St Master Bathroom Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-21      Client Sample ID: Bottle #106336  
 Collection Date: 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 323 E Main St Master Bathroom Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/8/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22051027  
 Date Reported: 6/8/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22051027  
**Received Date:** 5/23/2022 11:00:00 AM  
**Reported Date:** 6/8/2022 3:52:47 PM

Sample Information: 375 E Main St  
 Long Creek, OR 97856

**Lab ID:** 22051027-22      Client Sample ID: Bottle #106348  
 Collection Date: 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 323 E Main St Main Bath Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**Lab ID:** 22051027-23      Client Sample ID: Bottle #106329  
 Collection Date: 5/14/2022 9:00:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 323 E Main St Main Bath Tub

Trace Metals by EPA 200.8 ICP-MS							Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/4/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-01      Client Sample ID: 20120100-001BF  
 Collection Date: 1/28/2022 9:10:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: South Sink West Girls RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.640		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-02      Client Sample ID: 20120100-002BF  
 Collection Date: 1/28/2022 9:12:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: North Sink West Girls RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-03      Client Sample ID: 20120100-003SF  
 Collection Date: 1/28/2022 9:15:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: West Faucet West Janitor's Rm

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.887		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-04      Client Sample ID: 20120100-004SF  
**Collection Date:** 1/28/2022 9:14:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: East Faucet West Janitor's Rm

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.666		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-05      Client Sample ID: 20120100-005BF  
**Collection Date:** 1/28/2022 9:15:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: West Sink West Boys RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.863		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-06      Client Sample ID: 20120100-006BF  
**Collection Date:** 1/28/2022 9:10:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: East Sink West Boys RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.942		0.515	ppb	1	2/15/2022	15.0	A	


**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

Lab Order: 22020446  
 Received Date: 2/8/2022 1:45:00 PM  
 Reported Date: 2/18/2022 1:49:26 PM

Sample Information:

Lab ID: 22020446-07 Client Sample ID: 20120100-007CF  
 Collection Date: 1/28/2022 9:17:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: ELC Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.15		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-08 Client Sample ID: 20120100-008CF  
 Collection Date: 1/28/2022 9:16:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: Home Ec Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-09 Client Sample ID: 20120100-009KF  
 Collection Date: 1/28/2022 9:19:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: West Kitchen Sprayer

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.728		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446

Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

*See updated results - page 3, date 5-14-22*

Lab Order: 22020446

Received Date: 2/8/2022 1:45:00 PM

Reported Date: 2/18/2022 1:49:26 PM

Sample Information:

Lab ID: 22020446-10 Client Sample ID: 20120100-010KF  
 Collection Date: 1/28/2022 9:18:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: West Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	35.0	*	0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-11 Client Sample ID: 20120100-011KF  
 Collection Date: 1/28/2022 9:20:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: East Kitchen Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.563		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-12 Client Sample ID: 20120100-012KF  
 Collection Date: 1/28/2022 9:20:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: East Kitchen Sprayer

Trace Metals by EPA 200.8 ICP-MS						Analyst; SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.794		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP**

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



**NEILSON  
RESEARCH  
CORPORATION**

Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

**Analytical Report**

WO#: 22020446  
Date Reported: 2/18/2022

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

*See updated  
results - page 3,  
Date 5-14-22*

Lab Order: 22020446  
Received Date: 2/8/2022 1:45:00 PM  
Reported Date: 2/18/2022 1:49:26 PM

Sample Information:

Lab ID: 22020446-13 Client Sample ID: 20120100-013KF  
Collection Date: 1/28/2022 9:20:00 AM Collected By: Jennie Freeman  
Matrix: Drinking Water Sample Location: Library Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-14 Client Sample ID: 20120100-014CF  
Collection Date: 1/28/2022 9:24:00 AM Collected By: Jennie Freeman  
Matrix: Drinking Water Sample Location: West Double Sink Science Lab

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	28.3	*	0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-15 Client Sample ID: 20120100-015CF  
Collection Date: 1/28/2022 9:19:00 AM Collected By: Jennie Freeman  
Matrix: Drinking Water Sample Location: NW Sink Science Lab

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	9.31		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits





Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-16      Client Sample ID: 20120100-018CF  
 Collection Date: 1/28/2022 9:20:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: North Sink Science Lab

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.25		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-17      Client Sample ID: 20120100-019CF  
 Collection Date: 1/28/2022 9:20:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: NE Sink Science Lab

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.86		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-18      Client Sample ID: 20120100-020CF  
 Collection Date: 1/28/2022 9:26:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: East Sink Science Lab

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.86		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-19      Client Sample ID: 20120100-021NS  
 Collection Date: 1/28/2022 9:21:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Nurse's Office Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.45		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-20      Client Sample ID: 20120100-022BF  
 Collection Date: 1/28/2022 9:30:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: South Sink East Boys RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.31		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-21      Client Sample ID: 20120100-023BF  
 Collection Date: 1/28/2022 9:30:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Middle Sink East Boys RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.09		0.515	ppb	1	2/15/2022	15.0	A


QUALIFIERS

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-22      Client Sample ID: 20120100-024BF  
 Collection Date: 1/28/2022 9:30:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: North Sink East Boys RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.556		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-23      Client Sample ID: 20120100-025SF  
 Collection Date: 1/28/2022 9:33:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: East Janitor's Closet Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.44		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-24      Client Sample ID: 20120100-027BF  
 Collection Date: 1/28/2022 9:41:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: South Sink East Girls RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.15		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

Lab Order: 22020446  
 Received Date: 2/8/2022 1:45:00 PM  
 Reported Date: 2/18/2022 1:49:26 PM

Sample Information:

Lab ID: 22020446-25 Client Sample ID: 20120100-028BF  
 Collection Date: 1/28/2022 9:40:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: 2nd Sink From Rt East Girls RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.93		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-26 Client Sample ID: 20120100-029BF  
 Collection Date: 1/28/2022 9:40:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: North Sink East Girls RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.53		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-27 Client Sample ID: 20120100-030SF  
 Collection Date: 1/28/2022 9:41:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: Staff Room Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.34		0.515	ppb	1	2/15/2022	15.0	A	

QUALIFIERS

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-28      Client Sample ID: 20120100-031CF  
 Collection Date: 1/28/2022 9:41:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Sink Faucet English Classroom

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.38		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-29      Client Sample ID: 20120100-033CF  
 Collection Date: 1/28/2022 9:44:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Sink Faucet Jr High Classroom

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.92		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-30      Client Sample ID: 20120100-035CF  
 Collection Date: 1/28/2022 9:45:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Sink Faucet 4-6 Classroom

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.87		0.515	ppb	1	2/15/2022	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-31      Client Sample ID: 20120100-036CF  
 Collection Date: 1/28/2022 9:45:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Drinking Faucet 4-6 Classroom

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.40		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-32      Client Sample ID: 20120100-037CF  
 Collection Date: 1/28/2022 9:48:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Sink Faucet East Computer Lab

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.36		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-33      Client Sample ID: 20120100-039CF  
 Collection Date: 1/28/2022 9:49:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Sink Faucet K-3 Classroom

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.515	ppb	1	2/15/2022	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-34      Client Sample ID: 20120100-041CF  
 Collection Date: 1/28/2022 9:48:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Sink Faucet Art Room

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.67		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-35      Client Sample ID: 20120100-043CF  
 Collection Date: 1/28/2022 9:41:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: 3rd Sink From Rt East Girls RR

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.81		0.515	ppb	1	2/15/2022	15.0	A

**Lab ID:** 22020446-36      Client Sample ID: 20120101-003BF  
 Collection Date: 1/28/2022 10:07:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Boys Locker Room Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.85		0.515	ppb	1	2/15/2022	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

Lab Order: 22020446  
 Received Date: 2/8/2022 1:45:00 PM  
 Reported Date: 2/18/2022 1:49:26 PM

Sample Information:

Lab ID: 22020446-37 Client Sample ID: 20120101-004BF  
 Collection Date: 1/28/2022 10:07:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: Girls Locker Room Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.76		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-38 Client Sample ID: 20120101-006BF  
 Collection Date: 1/28/2022 10:03:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: North Boys Restroom Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.08		0.515	ppb	1	2/15/2022	15.0	A	

Lab ID: 22020446-39 Client Sample ID: 20120101-007BF  
 Collection Date: 1/28/2022 10:03:00 AM Collected By: Jennie Freeman  
 Matrix: Drinking Water Sample Location: North Girls Restroom Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.17		0.515	ppb	1	2/15/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits





Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-40      Client Sample ID: 20120102-001CF  
**Collection Date:** 1/28/2022 10:15:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: West Wall Faucet Wood Shop

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	2/15/2022	15.0	A	

**Lab ID:** 22020446-41      Client Sample ID: 20120102-002BF  
**Collection Date:** 1/28/2022 10:15:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: Bathroom Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	2/14/2022	15.0	A	

**Lab ID:** 22020446-42      Client Sample ID: 20120109-001BF  
**Collection Date:** 1/28/2022 9:11:00 AM      Collected By: Jennie Freeman  
**Matrix:** Drinking Water      Sample Location: Boys Bathroom Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.822		0.515	ppb	1	2/14/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- CI Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 22020446  
 Date Reported: 2/18/2022

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 22020446  
**Received Date:** 2/8/2022 1:45:00 PM  
**Reported Date:** 2/18/2022 1:49:26 PM

Sample Information:

**Lab ID:** 22020446-43      Client Sample ID: 20120109-002DW  
 Collection Date: 1/28/2022 10:11:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Drinking Fountain North Wall

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	2/14/2022	15.0	A	

**Lab ID:** 22020446-44      Client Sample ID: 20120109-003BF  
 Collection Date: 1/28/2022 10:09:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Girls Bathroom Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.609		0.515	ppb	1	2/14/2022	15.0	A	

**Lab ID:** 22020446-45      Client Sample ID: 20120109-004KF  
 Collection Date: 1/28/2022 9:11:00 AM      Collected By: Jennie Freeman  
 Matrix: Drinking Water      Sample Location: Kitchen Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.11		0.515	ppb	1	2/14/2022	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits