

Long Creek School District #17 Radon Testing Results	June 2020	
---	------------------	--

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of Test	Results (pCi/L)
Long Creek School District #17	Gymnasium	Gym	4918332	6/6-6/9, 2020	Detector Kit	1.1
Long Creek School District #17	Long Creek School	Junior High Room	4918219	6/6-6/9, 2020	Detector Kit	1.1
Long Creek School District #17	Long Creek School	Cafeteria	4949487	6/6-6/9, 2020	Detector Kit	1.1
Long Creek School District #17	Long Creek School	Science Room	4949531	6/6-6/9, 2020	Detector Kit	1.1
Long Creek School District #17	Long Creek School	Cafeteria - duplicate	4949751	6/6-6/9, 2020	Detector Kit	1.2
Long Creek School District #17	Long Creek School	Cafeteria - duplicate	4949351	6/6-6/9, 2020	Detector Kit	1.5

The spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.